


# Study of the post-combustion CO<sub>2</sub> capture applied to conventional and partial oxy-fuel cement plants

Sinda LARIBI\*, Lionel DUBOIS, Guy DE WEIRELD and Diane THOMAS


Chemical & Biochemical Process Engineering and Thermodynamics Units, Faculty of Engineering, University of Mons, 20 Place du Parc, 7000 Mons, Belgium  
\*sinda.laribi@umons.ac.be

## Context of the study: CCU (Carbon Capture and re-Use)


In the context of Carbon Capture Storage (CCS) or Utilization (CCU), this work evaluates the application of the post-combustion CO<sub>2</sub> capture process by absorption-regeneration to cement plant flue gases coming from conventional and partial oxy-fuel kilns. The strategy of the study was to carry out a screening at lab scale (cables-bundle contactor) and then for the best solvents, at micro-pilot scale (absorption-regeneration micro pilot unit) of different amine(s) based solvents, especially to compare their absorption performances in a wide range of CO<sub>2</sub> contents into the gas phase (from 20 to 60 vol.%). Simulations were also conducted with Aspen Hysys™ of the application of the CO<sub>2</sub> capture process to highly CO<sub>2</sub>-concentrated flue gas in order to estimate the energy savings linked to the partial oxy-fuel conditions.



Source: adapted from Smart & Riley, 2012



ABSORPTION-REGENERATION PROCESS



Source: The Pembina Institute with Integrated CO2 Network (ICO2N)

## PARTIAL OXYFUEL COMBUSTION CAPTURE

## Experiments: Experimental devices, procedures & absorption results


### Lab scale: cables-bundle contactor

Operating parameter	Value
Pressure (P)	101.325 kPa
Inlet liquid temperature (T)	298.15 K
Liquid flow rate (L)	3.08 10 <sup>-4</sup> m <sup>3</sup> /s
Gas flow rate (G)	2.15 10 <sup>-4</sup> Nm <sup>3</sup> /s
CO <sub>2</sub> contents (Y <sub>CO2,in</sub> )	10 - 60 vol.-%

#### Two types of tests conducted:

Continuous tests: fresh scrubbing solutions (not CO<sub>2</sub>-loaded solutions at the inlet of the contactor) and a gas phase continuously fed in the contactor with varying CO<sub>2</sub> contents (Y<sub>CO2,in</sub> from 10 to 60 vol.%).

Semi-continuous tests: recirculation of 1.3 10<sup>-3</sup> m<sup>3</sup> of the solution fixing a CO<sub>2</sub> inlet content of 40 vol.% in the gas phase and allowing a progressive CO<sub>2</sub> loading of the solvent and following the temporal evolution of the absorption performances.




Amines investigated during the absorption tests at lab scale

Amine name	CAS number	Amine type	Abbreviation
Monoethanolamine*	141-43-5	primary alkanolamine	MEA
Dioethanolamine*	111-43-2	secondary alkanolamine	DEA
N-methyldiethanolamine	105-59-9	tertiary alkanolamine	MDEA
2-amino-2-methyl-1-propanol	124-68-5	sterically hindered alkanolamine	AMP
2-amino-2-hydroxyethyl-1,3-propanediol	77-86-1	sterically hindered alkanolamine	AHPD
Triethylenetetramine	112-24-3	tetramine	TETRA
Piperazine*	110-85-0	cyclical di-amine	PZ

\*Amines investigated also during the absorption-regeneration tests at micro-pilot scale.


### Results of the continuous absorption tests:

Comparison of the absorption performances of the solvents at different CO<sub>2</sub> contents into the gas phase (unloaded solutions):



### Results of the semi-continuous absorption tests:

Comparison of the absorption performances of the solvents at different experimental times (at Y<sub>CO2,in</sub> = 40%):



#### Analyses conducted and calculated parameters for the cables-bundle contactor and the micro-pilot unit:

- Gas analyses: CO<sub>2</sub> (IR)
- Liquid analyses: Total Organic Carbon (TOC) analyser: TC, IC, TOC + pH measurements
- The CO<sub>2</sub> loading  $\alpha_{CO_2}(t)$  [mol CO<sub>2</sub>/mol amine] can be determined at every moment of the absorption test:

$$\alpha_{CO_2}(t) = \frac{G_{CO_2}(t)}{C_{amine}(t=0)}$$

- The absorption efficiency (A (%)) of the solvent is calculated by:

$$A(\%) = \frac{G_{CO_2,abs} - G_{CO_2,in}}{G_{CO_2,in}}$$

- Based on A(%), the results can be explained in terms of the CO<sub>2</sub> molar absorption flow rate:

$$G_{CO_2,abs} \left( \frac{mol\ CO_2}{h} \right) = (A) * Y_{CO_2,in} * G_{in, dry}$$


#### Interpretation of experimental results:

The continuous tests with simple solvents: best absorption performances for PZ 10% and MEA 30%, the absorption results with TETRA 30% being also clearly higher than with the other solvents (AMP, DEA and AHPD 30%).

The continuous tests with activated solvents: for AMP 30% and DEA 30%, the activation effect is much more significant with PZ 5% than with TETRA 5%.

The semi-continuous tests: PZ activated solutions, and especially AMP 30% + PZ 5%, presents good absorption performances at the beginning of the test and also after 90 min with a significant CO<sub>2</sub> loading.

## Micro-pilot scale: Absorption-regeneration micro-pilot unit



#### Micro-pilot Unit (Pignat):


Experimental procedure: after humidification, the gaseous blend (composed of nitrogen and carbon dioxide) enters the absorption column where a counter-current contact between this gas mixture and the absorption solution is achieved at atmospheric pressure. The CO<sub>2</sub> loaded solution at the outlet of the absorption column is then preheated ("internal heat exchanger" positioned between the two columns through which the rich and lean solutions flow counter-currently) to the regeneration column where, by heating the solution up to its boiling point (maximum heating power of 2 kW), the CO<sub>2</sub> is liberated from the solution, regenerating the solvent which is pumped back to the absorption column.

#### Operating conditions:

Pressure [kPa]	101.325
T <sub>abs</sub> [°C]	40
T <sub>reg</sub> [°C]	95
T <sub>max</sub> [°C]	24
L <sub>abs</sub> and L <sub>reg</sub> [l/h]	7 to 24
G [Nm <sup>3</sup> /h]	960
H <sub>2</sub> O, ABS [m]	1
H <sub>2</sub> O, REG [m]	0.5
P <sub>boiler</sub> [kW]	2
C <sub>amine</sub> (max) [wt.-%]	35
CO <sub>2</sub> contents (Y <sub>CO2,in</sub> ) [vol.-%]	20 to 60

### Results of the micro-pilot absorption tests:

For the three selected solvents, the liquid flow rate was fixed at the beginning of the test leading to a steady absorption efficiency (A) value of around 90%.




#### Interpretation of the absorption results for the micro-pilot tests:

The effect of increasing Y<sub>CO2,in</sub> on the absorption-regeneration performances in terms of captured CO<sub>2</sub> amount (G<sub>CO2,abs</sub>): when Y<sub>CO2,in</sub> is increased, the same conclusion can be observed for G<sub>CO2,abs</sub>, even if the absorption performances of the three solvents are quite similar at Y<sub>CO2,in</sub> equal to 20%, G<sub>CO2,abs</sub> of DEA 30% + PZ 5% at Y<sub>CO2,in</sub> of 60% is higher than the one measured with the other solvents at the same Y<sub>CO2,in</sub> (better absorption performances).

The effect of increasing Y<sub>CO2,in</sub> on the absorption-regeneration performances in terms of regeneration energy (E<sub>regen</sub>): relatively to PZ 10 wt.-% (E<sub>regen</sub>/E<sub>regen</sub> PZ 10 wt.-% at Y<sub>CO2,in</sub> = 20%) which is the solvent leading to the highest E<sub>regen</sub> value at Y<sub>CO2,in</sub> equal to 20%, increasing Y<sub>CO2,in</sub> leads to a significant decrease of the solvent regeneration energy, especially for DEA 30% + PZ 5%.

## Simulations: Aspen Hysys™ simulations of the absorption-regeneration CO<sub>2</sub> capture process

#### Aspen Hysys™ flow sheet for the conventional MEA 30% process configuration:




#### Operating parameters (CASTOR/CESAR pilot unit):

G = 4000 Nm<sup>3</sup>/h, L = 22 m<sup>3</sup>/h

	Absorber	Stripper
Column Diameter [m]	1.1	1.1
Packing height [m]	17 (17 x 1 m)	10 (10 x 1 m)
Packing type	Random packing IMTP 50	Random packing IMTP 50
Inlet liquid temperature [°C]	40	110
Bottom pressure [kPa]	120	200
Linear pressure drop [kPa/m]	0.5	0.5

#### Flue gas compositions:

Component (mol. fract.)	Base case (Brevik)	ECRA simulations		
N <sub>2</sub>	0.647	0.575	0.488	0.399
CO <sub>2</sub>	0.204	0.310	0.441	0.514
H <sub>2</sub> O	0.062	0.062	0.048	0.056
O <sub>2</sub>	0.086	0.053	0.023	0.031
CO	1.33 10 <sup>-4</sup>	-	-	-
SO <sub>2</sub>	1.11 10 <sup>-4</sup>	-	-	-
NO	4.74 10 <sup>-4</sup>	-	-	-
NO <sub>2</sub>	1.77 10 <sup>-4</sup>	-	-	-



#### Aspen Hysys™ simulation results for different Y<sub>CO2,in</sub> values with MEA 30 wt.-%:

An increase of Y<sub>CO2,in</sub> leads to a significant decrease of the solvent regeneration energy. For the most favorable case (C) it can be seen that an increase of Y<sub>CO2,in</sub> from 20% to 44% leads to a decrease of 26% of the MEA 30 wt.-% regeneration energy (from 3.36 to 2.48 GJ/t<sub>CO2</sub>).

## Conclusions & prospects:

Screening at lab scale of different amine solvents in highly CO<sub>2</sub>-concentrated flue gases: comparison of absorption performances. ✓  
Experiments in micro-pilot unit: increasing the CO<sub>2</sub> content in the gas to treat allows a significant decrease of the solvent regeneration energy. ✓  
Simulations with MEA 30 wt.-%: increasing Y<sub>CO2,in</sub> from 20% to 44% leads to a decrease of the regeneration energy (37% when Y<sub>CO2,in</sub> is increased up to 60%). ✓  
Application of partial oxy-fuel combustion in a cement plant – good option that will be more deeply investigated (considering the oxygen production costs). ✓  
Future works: screening of solvents (both separate and combined screening experiments) with other simple and blended solutions with the associated simulations of the micro-pilot unit.

## Acknowledgements:

European Cement Research Academy (ECRA) and HeidelbergCement are acknowledged for the technical and financial supports accorded to the ECRA Academic Chair.